

FORM D

(Form of licence under sub - section (1) of section 6 of the Tamil Nadu Public Building (licensing) Act 1965 the Tamil Nadu) Act 13 1965 referred to in rule 6 of the Tamil Nadu Public Buildings (Licensing) Rules 1966.

L I C E N C E

Licence No. 14/2025

Fee Rs.5000/-
Remitted in Ch. No. 20250404011600
Dated: 04.04.2025.
Bank of Baroda, Perundurai.

Taluk Office,
Perundurai.
Dated : .04.2025.

Ref. No. K.Dis. 2270/2025/A3

Licence is here by granted to **THE CORRESPONDENT, M/s. KONGU INTERNATIONAL SCHOOL**, resident at **Muthaiyan Kovil, Vellode Road, Chennimalai**, Perundurai Taluk, Erode District, for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned here under:-


1. The period of validity of the Licence shall be Renewed from **01.06.2025 to 31.05.2028** (Inclusive of Both Days)


TAHSILDAR
PERUNDURAI

STATEMENT TO ACCOMPANY THE LICENCE

Location of the building Door No. Street No. and Name of the Place	Purpose for which the building is licensed to be used as a public building	No. of Persons to be accommodated.
R.S.F.No. 588/1B, 2B1, 2B2, 3, 588/4A, 6 & 589/3B Muthaiyan Kovil, Mugasipidariyur Village & Panchayat, Perundurai Taluk, Erode District.	TO RUN SCHOOL	600 Persons (Six Hundred only)

Dated : .04.2025




TAHSILDAR
PERUNDURAI.



STATEMENT OF ACCOMPANYING FORM - A

1. Name : THE CORRESPONDENT,
Kongu International School,
Muthaiyan Kovil, Vellode Road
Chennimalai- 638051,
- Survey number of the site : R.S.F.NO:588/1B,2B1,2B2,3,4A,6A,
589/3B
2. Location (Street Number, Ward Number)
- Name of Village : Mugasipidariyur Village
- Panchayat Union/Panchayat/Township/ : Mugasipidariyur Panchayat
- Cantonment Chrennimalai Union, Perundurai Taluk
Erode District
3. Year of Construction : 2017
4. Approximate cost of construction : Rs.2,52,000.00/-
5. Purpose for which the building is
being Used or purpose to be used : School Buildings Class Rooms & Toilet
6. Purpose for Which the Building has
Either To been used : School Buildings Class Rooms & Toilet
7. Details for construction of the building
(Particulars of the foundation soils,
Specification of the various parts under)
- (i). Foundation : RCC Column Footing
- (ii). Basement : R.R.M.in Cement Mortar & Plinth
Beam
- (iii). Super Structure : RCC Column Footing with load
Bearing Wall
- (iv). Floor and Roof : RCC Flat Roof & Polished Granite slab

8. Period for which licence is required : 3 Years

(01.06.2025 To 31.05.2028)

9. Carpet area of the building : 1874.04 Sq.mt

10. Number of persons To be accommodated : 600 Nos

Date: 03.04.2025

K.T. 3/4/25

Signature of the Owner of the

Building

CORRESPONDENT
Kongu International School ;
Chennimalai-638 051.

3/4/25

Signature of the Structural

Engineer

Er.S.GOPALAKRISHNAN.,B.E.,M.E.,(Str.),
AMIE.,CE(I),FIV.,MISTE.,
DISTRICT PANEL ENGINEER CLASS-1A,
REG. NO.R.DIS 16156/2020/C2. Dt.6.1.2022,
ERODE DISTRICT. PH 99652 66826.

STRUCTURAL SPECIFICATION

A. Framed structures with reinforcement cement concrete columns, beams & slabs.

- (i) Maximum span of the beam 5.88 meters.
- (ii) Maximum unsupported length of columns – nil.
- (iii) Maximum size of the column 450mm x 230mm.
- (iv) Maximum size of the beam 450mm x 230mm.

B. Design load on the structure.

- (i) Live load at floor level – 3.0 KN/Sq.m.
- (ii) Live load at Roof level – 1.5 KN/Sq.m.
- (iii) Live load for stair, corridor and balcony's – 4.0 KN/Sq.m.

C. Dead load assumed other than the self-weight.

- (i) For floor finishes – 1 KN/Sq.m.
- (ii) For partitions – 1.5 KN/Sq.m.
- (iii) For terrace finishes – 2 KN/Sq.m.

D. Other service loads as per actual.

- (i) Over Head Tank

FORM - B

(Form of certificate of structural soundness under sub – section (4) of section 4 of the Tamil Nadu public buildings (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 4 of the Tamil Nadu public buildings (Licensing) Rules, 1966).

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. Foundation


- (i) Depth below ground level : 2.10 m
- (ii) Nature of soil met with foundation level : Hard Gravel Rocky
- (iii) Pressures are foundation : 29.06 T/Sq.m.
- (iv) Probable safe bearing capacity of the
Strata met with at foundation : 40 T /Sq.m.

2. Super structure

- (i) Maximum stress in the most critical section
Masonry & concrete : Brick in CM – 32.08 T / Sq.m
Concrete - 250 Kgs / Sq.m
- (ii) Nature of masonry& concrete and its
Safe permissible stress : Brick in CM – 15 T / Sq.m
Concrete - 250Kgs / Sq .m

The structural soundness of the building has been verified by me with the reference to ISI loading standards 875 (Latest version) and other relevant Indian standards code of practice and I declare that the building for the purpose noted in the statement. A license may be granted for the period of 3 Years from 01.06.2025 To 31.05.2028.

Date: 03.04.2025


Signature of the Structural Engineer

Er.S.GOPALAKRISHNAN.,B.E.,M.E.,(Str.),
AMIE.,CE(I)..FIV..MISTE.,
DISTRICT PANEL ENGINEER CLASS-1A,
REG. NO:R.DIS 16156/2020/C2 Dt.6.1.2022,
ERODE DISTRICT. PH 99652 66826.

FORM - C

(Form of certificate of structural soundness under sub – section (4) of section 4 of the Tamil Nadu public buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rule 4 of the Tamil Nadu public buildings (Licensing) Rules, 1966).

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. Foundation


- (i) Depth below ground level : 2.10 m
- (ii) Nature of soil met with foundation level : Hard gravel
- (iii) Pressures are foundation : 29.06 T / Sq.m.
- (iv) Probable safe bearing capacity of the
Strata met with at foundation : 40 T / Sq.m.

2. Super structure

- (i) Maximum stress in the most critical section
Masonry & concrete : Brick in CM – 32.08 T/ Sq.m
- (ii) Nature of masonry & concrete and its
Safe permissible stress : Masonary – 15 T / Sq.m
RR Masonry – 45 T / Sqm

The structural soundness of the building has been verified by me with the reference to ISI loading standards 875 (Latest version) and other relevant Indian standards code of practice and I declare that the building for the purpose noted in the statement. A license may be granted for the period of **3 Years** from **01.06.2025 To 31.05.2028**.

Date: 03.04.2025



Signature of the Structural Engineer

Er.S.GOPALAKRISHNAN.,B.E.,M.E.,(Str.),
AMIE.,CE(I)..FIV..MISTE.,
DISTRICT PANEL ENGINEER CLASS-1A,
REG. NO:R.DIS. 16156/2020/C2. Dt.6.1.2022,
ERODE DISTRICT. PH 99652 66826,


STATEMENT TO ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS

- Location of the building : R.S.F.NO:588/1B,2B1,2B2,3,4A,6A,
589/3B
1. Name of the place : Mugasipidariyur Village & Panchayat
Perundurai Taluk
Erode District-638051
2. Age of the Building : 5 years
3. Numbers of storey : G+2 (BLOCK-I &II)
4. Type of short description of structures
R.C.C. Framed or load bearing masonry : RCC Framed Structures
5. Purpose for which the building is certify for use : School Buildings Class Room & Toilet
6. The period for which the building will be
Structurally sound : 01.06.2025 To 31.05.2028.
7. Number of persons to be accommodated : 600 Nos
8. Remarks : Good

Date: 03.04.2025


Signature of the Structural Engineer

Er.S.GOPALAKRISHNAN.,B.E.,M.E.,(Str.),
AMIE.,CE(I)..FIV..MISTE.,
DISTRICT PANEL ENGINEER CLASS-1A,
REG. NO:R.DIS. 16156/2020/C2. Dt.6.1.2022,
ERODE DISTRICT. PH 99652 66826.



Signature of the Owner of the Building
CORRESPONDENT
Kongu International School,
Chennimalai-638 051.

DECLARATION

I, Er.S.Gopalakrishnan.,B.E.,M.E.,(Str.),AMIE.,CE(I),FIV.,MISTE.,(Panel Engineer Erode District R.DIS.16156/2020/C2.Dt.6.1.2022) Son of Mr.Samiappan, 237-6, Sivam Nagar, Near Nallappas Theatre, Perundurai, Erode-638052.

Station : Perundurai

Date : 03.04.2025.



Signature of the Structural Engineer

Er.S.GOPALAKRISHNAN.,B.E.,M.E.,(Str.),
AMIE.,CE(I),FIV.,MISTE.,
DISTRICT PANEL ENGINEER CLASS-1A,
REG. NO R DIS 16156/2020/C2 Dt 6.1.2022,
ERODE DISTRICT. PH 99652 66826.